

«MAGNITO-KONTAKT» Ltd

51B, place H4, Novaya St., 390027 Ryazan, Russia, phone +7 915 622-20-57 E-mail: olya374@rambler.ru; 451694@bk.ru http://www.m-kontakt.ru

SIGNALING DEVICE GAS C-ARTOL




Description


Signaling device gas C-ARTOL is designed for the detection of hazardous concentrations of combustible gases (methane or propane-butane mixture) in industrial or residential applications. Issuance of visual and sound signals on the attainment of maximum permissible

concentrations of combustible gases in the air. Overlap of the gas pipe manipulator or electromagnetic pulse valve with a supply voltage of 12V and/or electromagnetic pulse valve with voltage of 220V, and the issuance of the notice of the alarm at the remote Central control or the control panel.

Dimensions

Dimensions in mm





Technical characteristics

Voltage	12V
Current consumed by the signaling device in standby	not more 200mA
mode	
Current consumed by the signaling device in the	not more 300mA
alarm mode	
Time of technical readiness of the device to work	not more 60s
Response time of the signaler	not more 15s
Volume level of the audio signal	not more 82 db
Dimensions	Ø98*36mm
Weight	0.3kg
Operating temperature	+10+50°C
Humidity	95%

ATTENTION! Obligatory observance of polarity of the power source